

Water Sample Results for Lead
Onondaga Central School District
Wheeler Elementary School
Sampling Date: 02/10/2021

Room Name	Location/Type	Sample Number	LSL Sample ID	Lead Content Stock	mg/L	Quantity	ppb	Date Sampled	Remediation Plan
	101 Class Rm Sink2	Wes 1	2101900-001A	0.0044	mg/L	4.4	ppb	2/10/2021	OCS#1
	102 Class RM Sink L	Wes 2	2101900-002A	0.0020	mg/L	2.0	ppb	2/10/2021	OCS#2
	102 Classrm Sink r	Wes 3	2101900-003A	0.0021	mg/L	2.1	ppb	2/10/2021	OCS#3
	103 Classrm Sink r	Wes 4	2101900-004A	0.0094	mg/L	9.4	ppb	2/10/2021	OCS#4
	104 Classrm Sink	Wes 5	2101900-005A	0.0062	mg/L	6.2	ppb	2/10/2021	OCS#5
	105 Classrm Sink	Wes 6	2101900-006A	0.0076	mg/L	7.6	ppb	2/10/2021	OCS#6
	106 Classrm Sink	Wes 7	2101900-007A	0.0570	mg/L	57.0	ppb	2/10/2021	OCS#7 Lable Sink
	107 Classrm Sink	Wes 8	2101900-008A	0.0024	mg/L	2.4	ppb	2/10/2021	OCS#8
	108 Faculty Rm Sink	Wes 9	2101900-009A	0.0010	mg/L	1.0	ppb	2/10/2021	OCS#9
	109 Classrm Sink	Wes 10	2101900-010A	0.0031	mg/L	3.1	ppb	2/10/2021	OCS#10
	110 Bathroom Fixture	Wes 11	2101900-011A	0.0012	mg/L	1.2	ppb	2/10/2021	OCS#11
	111 Classrm Sink	Wes 12	2101900-012A	0.0049	mg/L	4.9	ppb	2/10/2021	OCS#12
	113 Classrm Sink	Wes 13	2101900-013A	0.0018	mg/L	1.8	ppb	2/10/2021	OCS#13
	115 Bathroom Fixture	Wes 14	2101900-014A	0.0010	mg/L	1.0	ppb	2/10/2021	OCS#14
	117 Bathroom Fixture	Wes 15	2101900-015A	0.0021	mg/L	2.1	ppb	2/10/2021	OCS#15
	119 Band RM sink	Wes 16	2101900-016A	0.0083	mg/L	8.3	ppb	2/10/2021	OCS#16
Co2 Corridor	BF#4	Wes 17	2101900-017A	0.0010	mg/L	1.0	ppb	2/10/2021	OCS#17
	120 PE Bath RM sink	Wes 18	2101900-018A	0.0031	mg/L	3.1	ppb	2/10/2021	OCS#18
	116 PE ice Maker	Wes 19	2101900-019A	0.0010	mg/L	1.0	ppb	2/10/2021	OCS#19
	128 BF#3	Wes 20	2101900-020A	0.0023	mg/L	2.3	ppb	2/10/2021	OCS#24
1 Left sink128	Kitchen outside W	Wes 21	2101900-021A	0.0021	mg/L	2.1	ppb	2/10/2021	OCS#25
sink 2 128	Kitchen outside W	Wes 22	2101900-022A	0.0023	mg/L	2.3	ppb	2/10/2021	OCS#26
Hall side 128	Kitchen sink	Wes 23	2101900-023A	0.0000	mg/L	0.0	ppb	2/10/2021	OCS#27
	126 Cafetorium DF#5	Wes 24	2101900-024A	0.0026	mg/L	2.6	ppb	2/10/2021	OCS#28
	135 Bathroon Sink	Wes 25	2101900-025A	0.0018	mg/L	1.8	ppb	2/10/2021	OCS#29
	142 Nurses office sink	Wes 26	2101900-026A	0.0016	mg/L	1.6	ppb	2/10/2021	OCS#31
C10 corridor	BF#7	Wes 27	2101900-027A	0.0010	mg/L	1.0	ppb	2/10/2021	OCS#27
	156 Classrm Sink	Wes 28	2101900-028A	0.0028	mg/L	2.8	ppb	2/10/2021	OCS#33
	158 Classrm Sink	Wes 29	2101900-029A	0.0076	mg/L	7.6	ppb	2/10/2021	OCS#32
	159 Library Sink	Wes 30	2101900-030A	0.0058	mg/L	5.8	ppb	2/10/2021	OCS#34
	160 Classrm Sink	Wes 31	2101900-031A	0.0045	mg/L	4.5	ppb	2/10/2021	OCS#36
	161 Girls Bath sink 1L	Wes 32	2101900-032A	0.0014	mg/L	1.4	ppb	2/10/2021	OCS#38
	162 Mens RM sink 4R	Wes 33	2101900-033A	0.0010	mg/L	1.0	ppb	2/10/2021	OCS#35
	164 Classrm Sink	Wes 34	2101900-034A	0.0150	mg/L	15.0	ppb	2/10/2021	OCS#37 Lable Sink
	166 Classrm Sink	Wes 35	2101900-035A	0.0031	mg/L	3.1	ppb	2/10/2021	OCS#39
	167 Classrm Sink	Wes 36	2101900-036A	0.0091	mg/L	9.1	ppb	2/10/2021	OCS#40
	168 Classrm Sink	Wes 37	2101900-037A	0.0060	mg/L	6.0	ppb	2/10/2021	OCS#41
	169 Classrm Sink	Wes 38	2101900-038A	0.0086	mg/L	8.6	ppb	2/10/2021	OCS#42
	170 Classrm Sink	Wes 39	2101900-039A	0.0071	mg/L	7.1	ppb	2/10/2021	OCS#43
	171 Classrm Sink	Wes 40	2101900-0340A	0.0045	mg/L	4.5	ppb	2/10/2021	OCS#44
	Bathroon Fixture	Wes		0.0000	mg/L	0.0	ppb	2/10/2021	OCS#
	Bathroon Fixture	Wes		0.0000	mg/L	0.0	ppb	2/10/2021	OCS#